

- One Set of Supply Connections Required for Five Stations
- Preassembled, Complete with Drain Fitting

# **Specifications**

#### Materials

All exposed parts are type 304 stainless steel or polished chrome-plated brass. Valve manifold is cast brass. Drain fitting is cast iron and supply inlets are copper tubing.

# **Standard Equipment**

## **Flow Control**

A 2.0 GPM (7.6 LPM) flow control is standard. Actual flow may vary, but will not exceed 2.5 GPM (9.5 LPM) Max.

### Column Shower

Constructed of type 304 stainless steel. Column and column cap are 16 gauge, and base flange is 13 gauge. Access panel located near bottom of column. Each station on column shower equipped with a stainless steel soap tray.

#### Drain Fitting

Cast iron with five stainless steel mounting bolts.

#### Supply Inlets

Constructed of 3/4" type "L" copper tubing.

# **Optional Privacy Compartments**

#### Partitions

Fabricated of 20 gauge 300 series stainless steel sheets polished to a #4 finish. Sandwich type construction with waterproof cores securely bonded between sheets. Partitions are secured to posts with 14 gauge type 300 stainless steel stirrups and stainless steel screws.

#### Posts

Fabricated 18 gauge 1-1/4" square x 80" stainless steel tubing. Post is secured to floor with an expansion anchor and a concealed foot angle which allows plus or minus 1/2" vertical adjustment.


#### Curtains

Curtain rails fabricated of 300 series #4 finish stainless steel cylindrical tubing. Curtain hooks are steel wire with a zinc chromate finish. Curtains are 60" W x 74" H and fabricated of heavy gauge translucent vinyl with hemmed edges and aluminum grommet reinforced eyelets.

#### Hardware

All exposed fasteners are vandal-proof stainless steel. Post shoes are anodized aluminum and finished to match stainless steel.

COL-2C, COL-3C, COL-4C, COL-5C 2 – 5-Person Column Showers



Plumbing Fixtures Document No. 5120

Page 1 of 3 This information is subject to change without notice. 3/5/2012 © 2012 Bradley P.O. Box 309, Menomonee Falls, WI 53052-0309 Phone: 800.BRADLEY(800.272.3539) Fax: 262.253.4161 bradleycorp.com



In Shower* In Shower* In Shower In Shower In Shower In supplies from below vent with supplies from above vent with supplies from below In supplies from above	
vent with supplies from above vent with supplies from below	
vent with supplies from above vent with supplies from below	
vent with supplies from below	
h supplies from above	
Showerhead Height (select one) G'-O" Standard Height	
□ 5'-6" Juvenile Height	
Valve Type (select one)   Hot/Tempered and Cold Supplies   EF Equa-Flo Pressure Balancing Valve	
ressure Balancing Valve	
lixing Valve	
ompression Valve* <i>ply</i> Ive	
ssion Valve	
etering Valve**	

\*Non-cancelable, non-returnable


 $^{\star\star}{\rm TT}$  Valves require optional 24V Class 2 transformers, available as a separate item from Bradley.

Verify all rough-in dimensions prior to installation.

Consult local and national codes: conformity and compliance to local and national codes is the responsibility of the installer.

Optional Selections Showerhead Variations	
🗆 SX	Severe Service Showerhead
🗆 SF	Deluxe Showerhead with Ball Joint
🗆 ES	Economy Soft Flow with Ball Joint
Flow Control (Not available with SF Showerhead)	
□G	1.5 GPM (5.7 LPM) Flow Control
Volume Control (Not available with SX or ES Showerhead)	
🗆 AKV	Allen Key Volume Control
🗆 THV	T-Handle Volume Control
Ball Joint (Not available with SX or ES Showerhead)	
🗆 LBJ	Lockable Ball Joint
Drain Variations	
🗆 CR	Clamping Ring for Flashing
🗆 DG	Dome Grate Drain
Miscellaneous	
🗆 ST	Stops in Supplies
🗆 SH	Telescoping Shroud
🗆 CS	Soap Container in Panel with Liquid Soap Valves*
🗆 FAK	Flange Anchor Kit
	Less Column Drain
	Less Drain Slots*
Multi-Stall Partitions	
□ MS	Multi-Stall Partitions
Multi-Stall Options	
🗆 HR	Herculite Curtain
🗆 RH	Roller Hooks
🗆 BH	Robe Hook

## **Drain Variations**§




See Document No. 5140 for drain rough-ins and column installation instructions.


**TYPE A** Supplies below. Vent off line.

TYPE B Supplies above.

Vent through column.



Supplies below. Vent through column.



**TYPE 0** Supplies above. Vent off line.





Page 2 of 3 This information is subject to change without notice. 3/5/2012 © 2012 Bradley P.O. Box 309, Menomonee Falls, WI 53052-0309 Phone: 800.BRADLEY(800.272.3539) Fax: 262.253.4161 bradleycorp.com




# COL-2C, COL-3C, COL-4C, COL-5C 2 – 5-Person Column Showers

## 2-Person Multi-Stall Dimensions













**3-Person Multi-Stall Dimensions** 









# 4 – 5-Person Multi-Stall Dimensions







Page 3 of 3 This information is subject to change without notice. 3/5/2012



© 2012 Bradley P.O. Box 309, Menomonee Falls, WI 53052-0309 Phone: 800.BRADLEY(800.272.3539) Fax: 262.253.4161 bradleycorp.com