## "QUALITY PUMPS SINCE 1939"

Product information presented here reflects conditions at time of publication. Consult factory regarding discrepancies or inconsistencies.



SHIP TO: 3649 Cane Run Road • Louisville, KY 40211-1961

(502) 778-2731 • 1 (800) 928-PUMP • FAX (502) 774-3624



**SECTION: 2.20.027** FM1779

Supersedes 0903

0404

visit our web site: htpp://www.zoeller.com

### **COMPARE THESE FEATURES**


- 115V single phase/60 Hz, 1/2 HP,
   5.0 Amps, 3400 RPM.
- Thermal overload protection.
- Non-corrosive engineered plastic motor housing, pump housing and base.
- · No steel sheet metal parts to rust or corrode.
- All stainless steel screws, switch arm, and lower motor housing.
- · Oil-free.
- 2-pole float operated mechanical switch.
- · Solid buoyant polypropylene float.
- · Engineered plastic impeller.
- · UL Listed 9' cord with 3-prong plug.
- Maximum temperature for dewatering -110°F. (43°C.)
- · Passes 3/8" spherical solids.
- 1½" NPT discharge.
- · Non-clogging vortex impeller.
- On point— 8-1/2" Off point— 3-5/8"
- Major width 9-1/16"
   Height 12-5/8"



# ALL MODELS ARE COMPLETELY SUBMERSIBLE HERMETICALLY SEALED

Watertight - dust tight.






# CONSULT FACTORY FOR SPECIAL APPLICATIONS

- Variable level Float Switches available.
- · Variable level long cycle systems available.
- · Alarm systems available.
- · Duplex systems available.

Single Seal	Control Selection					
Model	Volts	Phase	Mode	Amps	Simplex	Duplex
M76	115	1	Auto	5.0	1	3
N76	115	1	NonAuto	5.0	2	2 & 3

# TOTAL DYNAMIC HEAD/FLOW PER MINUTE DEWATERING ONLY

МО	DEL	76		
Feet	Meters	Gal.	Liters	
5	1.5	50	189	
10	3.0	40	151	
15	4.6	30	114	
20	6.1	17	64	
Shut-of	f Head:	25 ft. (7.6 m)		



- 1. Integral float-operated mechanical switch, no external control required.
- For automatic use single piggyback variable level float switch or double piggyback variable level float switch. Refer to FM0477.
- 3. See FM1663 for a residential alternator system.

#### ▲ CAUTION

For information on additional Zoeller products refer to catalog on Piggyback Variable Level Float Switches, FM0477; Electrical Alternator, FM0486; Mechanical Alternator, FM0495; Sump/Sewage Basins, FM0487; and Single Phase Simplex Pump Control/Alarm Systems, FM0732.

All installation of controls, protection devices and wiring should be done by a qualified licensed electrician. All electrical and safety codes should be followed including the most recent National Electric Code (NEC) and the Occupational Safety and Health Act (OSHA).

### **RESERVE POWERED DESIGN**

For unusual conditions a reserve safety factor is engineered into the design of every Zoeller pump.





MAIL TO: P.O. BOX 16347 Louisville, KY 40256-0347 SHIP TO: 3649 Cane Run Road Louisville, KY 40211-1961 (502) 778-2731 • 1 (800) 928-PUMP FAX (502) 774-3624

Manufacturers of..

"QUALITY PUMPS SINCE 1939"